CP/TF/01

TEST REPORT ON BITUMEN

Lab ID	:	**CP-2017-10-30-06** **Date: 31-10-17**
Customer	:	Assistant Executive Engineer, Yelahanka New Town Sub division, BBMP, Bangalore.
Address	:	Yelahanka New Town Sub division, BBMP, Bangalore.
Project Name	:	Improvements to roads at Pulakeshinagara in Attur Ward no.03
Agency	:	Sri. H.S. Palakshamurthy, No.1, 2nd Main, B. D. A layout, Pattegere, Palaya, Near Prashanthanagara, Bangalore.
Customer's Reference	:	EE(YNK.D)E-PMT-04/WO/107/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	30-10-17
Sample ID No	:	2017-10-30-06/01
Sample Type	:	Bitumen
Reference to BIS codes	:	IS: 1201-1220(1978) (Reaffirmed-2004)
Date of test	:	30-10-17

Test Results

Sl.no	Name of Test	Result	Requirements as per IS:73-
1	Penetration at 25°C , in 1/10th mm	65.3	60 to 70
2	Softening Point, °C	48.4	Min. 40°C
3	Ductility, cm	96	Min. 75cm
4	Flash point, °C	238	Min. 220°C
	Fire point, °C	246	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

AEW3

AE-03

CIVIL PRO Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com